



# Uttar Pradesh Medical Supplies Corporation Limited

(A Govt. of Uttar Pradesh Undertaking)

(CIN: U85310UP2018SGC102425)

Registered Office : SUDA Bhawan, 7/23, Sector-7, Gomti Nagar Extension, Lucknow-226010

E-Mail: [equipment@upmsc.in](mailto:equipment@upmsc.in) Website: [www.upmsc.in](http://www.upmsc.in) Contact Number: 0522-2838102

**Date- 05.06.2026**

**Tender Reference No.:- GEM/2026/B/7293406**

## **Technical Corrigendum-1**

**Name of Equipment:** Walk in Cooler

<b>Sr. No.</b>	<b>Reference Of Tender Clause</b>	<b>Tender Clause</b>	<b>Revised Clause</b>
<b>1.</b>	Floor Material	Aluminium chequered plates/stainless steel	Aluminium chequered plates or sheet
<b>2.</b>	Floor Material	Insulation thickness:- 100.0/200.0	Insulation thickness:- 100.0
<b>3.</b>	Physical Properties	Internal dimension (Inches):-Height must be 8 feet length and width may be customizable as per space availabilit.	Internal dimension:- Height must be 8 feet length and width may be customizable as per space availabilit.
<b>4.</b>	ATC Specification Refrigeration System Components	Height must be 8 feet length and Width may be customizable as per space availability. The internal Volume of WIC must be 40 CuM	Internal dimension:- Height must be 8 feet length and width may be customizable as per space availabilit.